



FIRE EXTINGUISHER ANNUAL CERTIFICATE OF INSPECTION

FOR

.....*Millennium Pavilion*.....

This certifies that the fire extinguishing appliances have been serviced in accordance with relevant British and European standard codes of practice with results indicated on the certificate of inspection.

It is recommended that regular inspection of all extinguishers, spare cartridges and replacement charges should be carried out by a responsible person at intervals, at least monthly to make sure appliances are in their proper position and have not been discharged or have lost pressure (in the case of extinguishers fitted with a pressure indicator) or suffered any obvious damage. If so contact S.S.S Tel. 01328 855253.

Date

.....*April 19*.....

Signature

.....*[Handwritten Signature]*.....